

EVACUATE

AA	Fire! Fire! Please leave the building. Fire! Fire! Leave the building.	DX	Attention please. Attention please. Will everybody leave the building by the nearest exit. This is a safety precaution, the staff will assist and direct you. Please do not use the lift.
AF	Fire detected. Keep calm. Leave the building by the nearest exit.	DZ	Ladies and gentlemen. Your attention please. We regret that due to circumstances beyond our control, we must ask you to leave the building. Please use the exits to the front of the auditorium and leave as quickly and quietly as possible. Wheelchair users please proceed to the nearest refuge point. Staff will assist you. Thank you."
AK	Fire emergency. Please remain calm and evacuate the building immediately.	EP	Attention, attention, there has been an incident within the building. Please evacuate via the nearest available exit.
AM	In the interest of safety, please evacuate the building immediately.	EU	Attention please. Attention please. Fire has been reported in the building.
AN	Attention! Attention! Please evacuate this floor immediately.	EV	Attention please. Attention please. Due to circumstances beyond our control we are unable to continue. Please leave the building immediately by the nearest exit.
AO	Attention! Attention! Please leave by the nearest exit.	EX	In the interest of safety please leave the building by the nearest exit as directed by members of staff.
AP	Attention! Attention! This is a fire emergency. Please evacuate the building.	EZ	Fire! Fire! Please evacuate the building.
AQ	In the interest of safety, please evacuate the building.	GF	Attention. Attention. Please evacuate the area. Do not return to or use your car.
AS	This is a fire alarm. Please evacuate the building.	GH	Ladies and gentlemen, in the interest of safety this building must be evacuated. Please leave immediately by the nearest exit. Staff will assist you.
AT	This is a fire alarm. Please evacuate the building immediately.	GL	In the interest of safety we must ask you to leave the building by the nearest exit or as directed by members of staff.
AU	Please evacuate. There is a fire incident.	GR	Please evacuate the building by the rear doors.
AX	We have an emergency situation. Please leave the building by the nearest exit. Members of staff will assist you.	GS	Please evacuate the building by the front doors.
AY	This is a fire alarm. Please leave the building. The fire brigade has been called.	GT	Please make your way to the basement by the internal staircase.
AZ	Ladies and gentlemen - due to unforeseen circumstances we must ask you to leave the building by the nearest exit, or as directed by members of staff.	HQ	Attention, attention, this is an emergency. Please leave the building by the nearest available exit. Do not use the lifts.
BA	Attention! Attention! An emergency situation has arisen. Please leave by the nearest exit. Do not use lifts or escalators.	HT	Fire emergency. Do not enter.
BC	An emergency situation has arisen within the stadium. Please leave the stadium in an orderly manner.	KU	May I have your attention please. May I have your attention please. An incident has been reported in the building. Please leave the building immediately by the nearest exit. Do not use the lifts.
BD	Fire emergency. Please evacuate.	LA	This is a fire alarm. Please evacuate the area immediately.
BG	This is an intelligent fire warning system. There is a fire in the building – evacuate now!	LQ	"This is a fire alarm! Please leave the building immediately by the nearest available exit"
CN	Leave the building immediately	LS	This is a fire alarm. This is a fire alarm.
CQ	Attention! Attention! Please evacuate the area. Do not return to or use your car.	MH	Attention please, attention please. Fire has been reported in the building. Please leave the building by the nearest exit. Do not use a lift.
CR	Ladies and gentlemen, in the interest of safety this building must be evacuated. Please leave immediately by the nearest exit. Staff will assist you.	MK	Attention please, attention please, will everybody leave the building by the nearest exit. This is a safety precaution, the staff will assist and direct you, please do not use the lifts.
CV	Attention! A situation has arisen where we need to clear the building. Please leave by the nearest exit or as directed by staff.	ML	Ladies and gentlemen, the building is being evacuated. Please leave by the nearest available exit.
CX	We have an emergency situation. Please leave the building by the nearest exit immediately.	MP	Attention please, attention please. This is an emergency evacuation, leave the building immediately and proceed to your nearest assembly point. Please do not use lifts or return to your cars.
CY	This is a General evacuation alarm, please leave the building immediately and proceed to the Car Park.	PK	There is a fire in this building, please leave by the door marked fire exit. I repeat, leave by the door marked fire exit. Do not go through reception.
CZ	This is a General evacuation alarm, please leave the building immediately, and proceed to your nearest assembly point.	PW	Attention please. We have an emergency within the building. Please leave by the nearest exit.
DB	In the interest of safety, please leave the building immediately by the nearest exit as directed by members of staff.	PX	Attention please. We have an emergency situation. Please do not enter the building.
DC	This is an evacuation alarm, please leave the building immediately and proceed to the Car Park.		
DD	This is an evacuation alarm, please leave the building immediately, and proceed to your nearest assembly point.		
DN	Attention! Attention! An emergency has arisen. Please leave by the nearest exit. Do not use lifts.		
DT	Attention please. Attention please, this is a fire emergency. Please leave the building by the nearest exit. Do not use the lift or escalators.		

TD Fire! Fire! Please leave the building. *English then French and then German.*

TG 4 seconds of two tone alert signal
2 seconds of silence
"Emergency, please leave the building by the nearest exit"
2 seconds of silence

TI Fire, Fire – Evacuate blue zone
(*yellow, green, red or orange also available*).

TS Fire! Fire! Please leave the building. Fire! Fire! Leave the building. *First in Arabic then in English*

UD Attention! Attention! This is a fire emergency. Please evacuate by the nearest exit.

UE Attention, please. Attention, please. Fire has been reported in the building. Please leave the building immediately, by the nearest exit. Do not use a lift.

UV Attention! Attention! There has been an incident within the building. Evacuate this area immediately.

VB Fire! Fire! Fire! Proceed to your nearest assembly point.

VG Attention! Attention! Please evacuate the area. Members of staff will assist you.

ALERT

AB This is a fire alert. This is a fire alert. Await further instructions. Await further instructions.

AW Fire! Fire! Do not enter.

KV May I have your attention please. May I have your attention please. An incident has been reported in the building. This report is being investigated. Further information will follow shortly.

PM Warning! There is a fire alarm activation in an adjoining area.

LE There is an emergency. Await further instructions.

LK Refuge point activation.

LR This is a fire alarm alert. Await further instructions.

LS This is a fire alarm. This is a fire alarm.

LT This is an emergency alert. This is an emergency alert. Await further instructions. Await further instructions.

ALL CLEAR

AD All clear. All clear. No further action required.

AR The fire emergency is cancelled. Please return to your place of work.

BE The fire test has been completed. Please return to your place of work.

BF The fire emergency is now cancelled. We apologise for any inconvenience.

UG The fire alarm test is now complete.

LF Alarm test now completed.

LZ All clear. No further action required. All clear. No further action required.

PY All clear. All clear. No action required.

STANDBY

AL This is a fire warning. Please remain calm, stay where you are. Await further instructions.

AV Please stand by. There is a fire incident.

CU Attention! An incident has been reported. Please stand by for further instructions.

EO Attention, attention, there has been an incident within the building. There is no need to evacuate. Please await further instructions.

HP Attention please, we are investigating an alarm condition. It may be necessary to evacuate the building. Please listen for further announcements.

MI Attention please, attention please. Fire has been reported in the building. This report is being investigated. Please listen for further instructions.

PA There is a fire in your area. Please await further instructions.

PB This is a fire alert. Please await further instructions.

UF May I have your attention, please. Fire has been reported in the building. Please listen for further instructions.

GAS / CHEMICAL RELEASE

AH Halon gas release imminent. Vacate area immediately.

AI Carbon dioxide gas release imminent. Vacate area immediately.

AJ Extinguishant gas release imminent. Vacate area immediately.

BM Extinguishant gas release imminent. Please evacuate the area.

BN Extinguishant gas system discharged.

BO Extinguishant gas discharged. Do not enter.

BU Toxic gas has been discharged. Evacuate the area immediately.

BV Please evacuate the area. Toxic gas released. Toxic gas released.

CE Excessive carbon monoxide levels have been detected. Please leave the area immediately.

CF Attention! Attention! Gas detected. Please evacuate the area.

CG First stage extinguishant release warning.

CH Second stage extinguishant release warning.

CI Extinguishant release imminent.

CJ Extinguishant released.

CO Please leave the room immediately; gas release imminent. Please leave the room and close the door.
Gas release in 10 seconds.
Please leave the room and close the door immediately.
Gas release in 5 seconds.
Gas released; do not open the door unless absolutely necessary.
Gas released.

DP First stage extinguishant release warning. Please evacuate the area. Evacuate the area.

DQ Argonite gas discharge imminent. Vacate area immediately. Vacate area immediately.

DR Argonite gas discharged. Do not enter. Do not enter.

DV Extinguishant gas system activated.

DY Please leave the room immediately; gas release imminent. Please leave the room and close the door.

EA Warning, warning, the extinguishing gas has been released in the Computer Room.

EB Warning, warning, the extinguishing gas is about to be released in the Computer Room.

EC Alert, alert, there is an alarm in the Computer Room.

ED Fire, fire, there is a fire alarm in the Computer Complex.

GA Excessive carbon monoxide levels have been detected. Please leave the area immediately.

GB Attention. Attention. Gas detected. Please evacuate the area.

GX Acid spillage, please evacuate immediately.

GY Acid spillage, all clear.

HC Attention. Acid spillage. Evacuate immediately.

HD Attention. Corrosive gas leakage. Evacuate immediately.

HE Attention. Chlorine gas leakage. Evacuate immediately.

HF Attention. Poisonous gas leakage. Evacuate immediately.

HG Attention. Toxic gas leakage. Evacuate immediately.

HI Refrigerant gas detection alarm activated. Immediate action required.

HJ Humidity detection alarm activated. Immediate action required.

HK High temperature detection alarm activated. Immediate action required

HL Infra-red detector activated. Immediate action required.

HN Overflow alarm activated. Immediate action required.

HO Float alarm activated. Immediate action required.

LB Attention! Attention! Please leave the room immediately. The oxygen level has dropped below the safe limit.

LC Attention! Attention! Oxygen levels are now above the permitted levels. Immediate attention required.

LG System is now in manual mode.

LH System is now in automatic mode.

LL Warning, low temperature. Please close all external doors.

LM Warning, high temperature. Please open all external doors.

LU Extinguishant gas release on hold.

LV Extinguishant gas release button is on hold.

KO Methane Gas detected in pump sump room.

SR Inergen gas discharge imminent. Please evacuate the area.

SS Inergen gas system has been discharged

ST Inergen gas discharged. Do not enter.

SU FM 200 gas discharge imminent. Please evacuate the area.

SV FM 200 gas system has been discharged.

SW FM 200 gas discharged. Do not enter.

SX Argonite gas discharge imminent. Please evacuate the area.

SY Argonite gas system has been discharged

SZ Argonite gas discharged. Do not enter

TA FE-36 gas discharge imminent. Please evacuate the area.

TB FE-36 gas system has been discharged.

TC FE-36 gas discharged. Do not enter.

TN Pyrogen extinguishant gas release imminent. Vacate area immediately.

TO Pyrogen extinguishant gas release imminent. Please evacuate the area.

TP Pyrogen extinguishant gas system discharged.

TQ Pyrogen extinguishant gas discharged. Do not enter.

TZ Please leave the room immediately; gas release imminent.

UX Warning, gas detected. Please enter with caution.

XI Danger, SF6 leak detected. Evacuate the area.

XJ Danger, low oxygen level. Evacuate the area.

TEST MESSAGE

AC This is a fire alarm test. No action required. No action required.

AE Fire alarm test now complete.

AG Alarm test only. No action required.

GQ Ladies and gentlemen. this is a test. No action is required.

HR This is a test of the public address system. This is a functional test for system operation, loudspeaker coverage, signal level and speech intelligibility.

HW Alarm test now complete.

KW May I have your attention please. May I have your attention please. The fire system is about to be tested. Please take no further action.

KX May I have your attention please. May I have your attention please. The fire alarm test is now complete. Thank you for your co-operation.

LY This is a fire alarm test. No action required. This is a fire alarm test. No action required.

TF This is a fire alarm test. No action required. No action required – *First in Swedish then in English.*

WATER ALARM

BH Water detection alarm activated. Immediate attention required.

HN Overflow alarm activated. Immediate action required.

HO Float alarm activated. Immediate action required.

WARNING / DANGEROUS OR HAZARDOUS AREAS

BB Attention! Fire shutter closing.

BP Attention. Attention. Hazardous area. Do not enter.

BQ Warning. Dangerous area. Do not enter.

BR Danger. Danger. Do not enter.

BS This is a hazardous area. Do not enter.

BT This is a dangerous area. Do not enter.

BW You are entering a hazardous area. Personal protective equipment should be worn.

BX This is a hazardous area. Authorised personnel only.

BY Fire shutter closure imminent. Please stand clear.

BZ Attention. Attention. Fire shutter closing.

CA Warning. Fire door closing. Stand clear.

CB Danger. Fire door closing. Please stand clear.

CW Shutter closing.

DA This is a site alarm, please stay in your Office and close all windows.

DE Caution, train approaching

DF Caution there is a train approaching.

DH Warning. Door activated. Stand clear!

DS Warning. Fire door activated. Stand clear.

EY Caution, door is about to operate.

GK Warning. Watertight door closing. Stand clear.

GO Warning. Fire curtain closing. Please stand clear.

GP	Danger. Fire curtain closing.
GU	Warning. Warning. Fire alarm activated.
GW	Lorry fire, close loading dock doors.
GZ	Warning, stand clear of all machinery. Warning, stand clear of all machinery.
HH	Warning. Alarm system setting. Press escape to abort.
HS	Door alarm will sound if the door is not closed.
MB	Fire alarm activated. Do not enter.
MQ	Domestic sprinkler system operated. Please inform the fire brigade immediately.
MR	Caution, the door is now opening.
PH	Warning, warning, system fault.
PI	Propane alarm, do not use this door. Use alternative exit when red light is flashing.
PJ	Danger, molten metal.
UA	Do not enter.
UH	Caution! Caution! Smoke vent opening.
VA	Stand clear. Shutter closing.
VE	Warning, an alarm condition exists and entry is forbidden until the alarm condition ceases or becomes silent.
XK	The fire alarm sprinkler system has operated. Please contact the fire brigade.
XL	The fire alarm detection system has operated.
XO	Safety shutter about to close. Stand clear.

CODED WARNINGS

GI	Staff 200
CK	Would Mr Marshal please report to the office.
DW	Help needed at 132 room.
MA	Standby alert. Close all blinds and move to the middle of the room.

INSTRUCTION / INFORMATION

BI	This is a no-smoking area. Please extinguish all smoking material.
BL	This is a no-smoking area. Please refrain from smoking, thank you.
BJ	This is a no-smoking area. Please refrain from smoking.
BK	No smoking please - this is a no smoking area.
CL	Attention! Attention! Would all managers report to the office.
CM	This site is private property. Please leave immediately
CP	Fire alarm is sounding. Close the door to the service corridor.
CS	This is private property. You are under CCTV surveillance. Leave immediately.
CT	This site is private property. You are being recorded by CCTV cameras and the police have been contacted.
DG	This is a staff call, all managers to report to their offices.
DK	This is a call for staff assistance.
DM	This is a staff alert.
GM	Would designated personnel please carry out a security search.
GN	Please report back to your nearest supervisor.
GV	Fire alarm activated, security notified.

KZ	Emergency use only. Please replace fire extinguisher.
LJ	Warning! Bollards rising.
LK	Refuge point activation.
MD	This is a staff call.
MW	Attention, this is a no smoking area, please use the smoking shelter provided. Thank you for your co-operation.
PS	Caution. This gate is about to close.
PT	Caution. This gate is about to open.
PU	Intelligent safety system activated. Please stand clear.
PV	Isolation switch activated. This gate will not function normally..
TH	Unsynchronised bell sound.
UO	Attention. Close shutter.
VF	Emergency assistance required at poolside.
XV	Your request for assistance has been recognised. A member of staff will be with you shortly.
XW	This is a Security Alert. Please collect your belongings and leave the building.

SECURITY ALERTS / WARNINGS

HY	This is a security alert. Please leave the building by the nearest exit.
HZ	There has been a security breach. Please leave the building as directed by staff.
MC	This is a security alert. Please leave the building as directed by staff.
PU	Intelligent safety system activated. Please stand clear.
PV	Isolation switch activated. This gate will not function normally
XZ	Please be aware that safety lighting will illuminate this area in thirty seconds.

CLASS CHANGE ANNOUNCEMENTS

CC	This is a class change announcement.
CD	End of period.

HOSPITAL INSTRUCTION / MEDICAL ALERT

DJ	This is a call for medical assistance.
DL	This is a medical alert.
UQ	Please remember to wash your hands with the gel provided.
PR	The hospital is now smoke free and smoking is not permitted anywhere in the buildings or within the hospital grounds. Thank you for your co-operation.

Next patient

This is a call for medical assistance

This is a diagnostic call / nurse call / pharmacy call / physiotherapy call / staff call

Messages are available in French, German, Spanish, Swedish, Welsh, and Turkish.

Other languages also available on request.